

Tucumcari

Consumer Confidence Report

2019

Is my water safe?

Last year, as in years past, your tap met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from 10 wells which are between 300 and 400 feet deep and are in the Entrada Sandstone Formation and Alluvial Aquifer.

Source water assessment and its availability

The Tucumcari Water System is well maintained and operated, and sources of drinking water are generally protected from potential sources of contaminations based on well construction, hydrogeologic settings, and system operations and management. In July 2003, the New Mexico Environment Department-Drinking Water Bureau issued a Source Water Assessment and Protection Program (SWAPP) report for the Tucumcari Water System. Findings of the SWAPP report indicate that the source susceptibility rank of the entire water system is High. Please contact the Tucumcari Water System to discuss the findings of the SWAPP report.

Table 8

SOURCE SUSCEPTIBILITY RANKING

Source Name	Sensitivity Rank	Vulnerability Rank	Susceptibility Exceptions	Operational Rank	Final
Hoover Well #1	Moderate	High	Moderately High -		Moderately High
Hoover Well #2	Moderate	High	Moderately High		Moderately High
Metro Well #4	Moderately Low	Low	Moderately Low -		Moderately Low
Metro Well #6	Moderately Low	High	Moderately High	>3 PSOC	High
Metro Well #7	Moderate	Low	Moderately Low	>3 PSOC	Moderate
Metro Well #8	Moderate	Low	Moderately Low	>3 PSOC	Moderate
Metro Well #10a	Moderate	Low	Moderately Low	>3 PSOC	Moderate
Metro Well #15	Low	Low	Moderately Low	>3 PSOC	Moderate
Town Well #12A	Moderately Low	High	Moderately High	>3 PSOC	High
Town Well #13	Moderate	Low	Moderately Low	Nitrate Monitoring-	Moderate
Town Well #16	Moderately Low	High	Moderately High	>3 PSOC	High
Town Well #17a	Moderate	High	Moderately High	>3 PSOC	High
Town Well #18	Moderate	High	Moderately High	>3 PSOC	High
Town Well #19	Moderately Low	High	Moderately High	>3 PSOC	High
Town Well #20	Moderately Low	High	Moderately High	>3 PSOC	High

PSOC: Potential Source of Contaminants

1New Mexico Environment Department, 2003. Source Water Assessment & Protection Program Report of Tucumcari Water Utility, Public Water System #28020, July 2003.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

You can attend City Commission meetings the second and fourth Thursday of each month.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Tucumcari Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Results of Radon Monitoring

Radon is a radioactive gas that you can't see, taste, or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. Fix your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that aren't too costly. For additional information, call your state radon program or call EPA's Radon Hotline (800-SOS-RADON).

Significant Deficiencies

On August 29, 2018 the NMED DWB conducted a regularly scheduled inspection of the Tucumcari Water System. The results of this inspection are detailed in the 2018 Sanitary Survey Report which is available from the Tucumcari Water System. A total of seventeen Significant deficiency was identified during the survey and two minor deficiencies were identified during the inspection. Those deficiencies were, lack of screens on and incorrect elevation of air relief, cross contamination at Treatment Plant, poor housekeeping of system facilities, storage tanks have leaks, storage tanks not secured from the elements, inadequate site security at major facilities, and inadequate sampling locations. All the deficiencies, except the two cement storage tanks leaking, were corrected immediately after being identified. An extension for has been filed for both tanks with the NMED DWB. The two minor deficiencies were entry sample point not above grade and sanitary seal inadequate. Both deficiencies were corrected immediately. A significant deficiency extension request was submitted on July 16, 2019 for storage tank #4 (11th street cement) which has multiple leaks. This tank was taken offline January 17, 2020 in compliance with this extension.

Monitoring and Reporting

We had tested positive for Bac-T samples on 8/5/2019 and 8/12/2019. Resamples were taken immediately in both cases as per state regulations. All repeat samples were cleared. There were no violations issued.

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing. The Tucumcari Water System did not report disinfectant residuals collected from the 3rd quarter of 2017.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Additionally, we are required to submit monitoring data to the state for the various drinking water standards. Tucumcari Water System is required to submit a report of the monthly disinfectant residuals on a quarter basis to the New Mexico Environment Department Drinking Water Bureau (NMEDDWB). Tucumcari Water System did not meet the monitoring and reporting requirements for this drinking water regulation. This resulted in a violation.

What should you do?

There is nothing you need to do at this time.

What does this mean?

The quality of the water is not compromised; however, failure to report precise disinfectant residuals is a requirement of the drinking water regulations.

What happened?

The residuals were taken during the 3rd quarter of 2017 but due to a changing of the superintendent position the report was never filed with the state.

What is being done?

Since this incident happened the reports have been filed on time with the state and the Assistant Water Superintendent also has been trained in filing the quarterly reports with the state.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT,</u> or <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	2.71	1.69	2.71	2019	No	By-product of drinking water chlorination
Chlorine (as Cl ₂) (mg/L)	4	4	0.9	.03	0.9	2019	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	15.1	6.92	15.1	2019	No	By-product of drinking water disinfection
Inorganic Contaminants								
Arsenic (ppb)	0	10	2	ND	2	2017	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Chromium (ppb)	100	100	1	ND	1	2017	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	200	200	13	ND	13	2017	No	Industrial contamination
Fluoride (ppm)	4.0	4.0	1.15	0.74	1.15	2017	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Nitrate [measured as Nitrogen] (ppm)	10	10	1.41	1.03	1.41	2019	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
--------------------------------------	----	----	------	------	------	------	----	---

Water Quality Data Table (cont.)

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT,</u> or <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>			
Inorganic Contaminants								
Selenium (ppb)	50	50	11	5	11	2017	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Sodium (optional) (ppm)		MPL	150	64	150	2014	No	Erosion of natural deposits; Leaching
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	8.1	8.1	8.1	2017	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	0.46	0.25	0.46	2017	No	Erosion of natural deposits
Beta/photon emitters (pCi/L)	0	50	9.9	9.1	9.9	2017	No	Decay of natural and man-made deposits. The EPA considers 50 pCi/L to be the level of concern for Beta particles.
Uranium (ug/L)	0	30	20	15	20	2017	No	Erosion of natural deposits
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds</u> <u>AL</u>	<u>Typical Source</u>	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.11	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	3	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
mg/L	mg/L: Number of milligrams of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
MFL	MFL: million fibers per liter, used to measure asbestos concentration
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Michael Martinez
Address:
P.O. Box 1188
Tucumcari, NM 88401
Phone: (575) 461-3923
Fax: (575) 461-5994
E-Mail: michael@cityoftucumcari.com
Website: cityoftucumcari.com